

**DWT6 10'-10000 COMPARTMENT**  
**38,825 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.6	14	31.1	1,789	61.6	5,142	92.1	9,478	122.6	14,425
1.3	25	31.8	1,846	62.2	5,223	92.7	9,576	123.2	14,532
1.9	38	32.4	1,903	62.9	5,306	93.3	9,674	123.8	14,640
2.5	52	33.0	1,961	63.5	5,388	94.0	9,773	124.5	14,747
3.2	68	33.7	2,020	64.1	5,471	94.6	9,872	125.1	14,855
3.8	86	34.3	2,079	64.8	5,555	95.3	9,971	125.7	14,962
4.4	104	34.9	2,139	65.4	5,638	95.9	10,070	126.4	15,070
5.1	125	35.6	2,199	66.0	5,723	96.5	10,169	127.0	15,178
5.7	146	36.2	2,261	66.7	5,807	97.2	10,269	127.6	15,286
6.3	169	36.8	2,322	67.3	5,892	97.8	10,369	128.3	15,394
7.0	193	37.5	2,384	67.9	5,978	98.4	10,469	128.9	15,502
7.6	219	38.1	2,447	68.6	6,063	99.1	10,570	129.5	15,611
8.3	245	38.7	2,511	69.2	6,150	99.7	10,671	130.2	15,719
8.9	273	39.4	2,575	69.8	6,236	100.3	10,772	130.8	15,827
9.5	301	40.0	2,639	70.5	6,323	101.0	10,873	131.4	15,936
10.2	331	40.6	2,704	71.1	6,410	101.6	10,974	132.1	16,045
10.8	361	41.3	2,770	71.8	6,498	102.2	11,076	132.7	16,153
11.4	393	41.9	2,836	72.4	6,586	102.9	11,177	133.3	16,262
12.1	426	42.5	2,903	73.0	6,674	103.5	11,279	134.0	16,371
12.7	459	43.2	2,970	73.7	6,763	104.1	11,382	134.6	16,480
13.3	494	43.8	3,038	74.3	6,852	104.8	11,484	135.3	16,589
14.0	529	44.5	3,107	74.9	6,942	105.4	11,587	135.9	16,698
14.6	565	45.1	3,176	75.6	7,031	106.0	11,690	136.5	16,808
15.2	603	45.7	3,245	76.2	7,122	106.7	11,793	137.2	16,917
15.9	641	46.4	3,315	76.8	7,212	107.3	11,896	137.8	17,026
16.5	680	47.0	3,386	77.5	7,303	107.9	11,999	138.4	17,136
17.1	720	47.6	3,457	78.1	7,394	108.6	12,103	139.1	17,245
17.8	760	48.3	3,528	78.7	7,486	109.2	12,207	139.7	17,354
18.4	802	48.9	3,600	79.4	7,577	109.9	12,311	140.3	17,464
19.0	844	49.5	3,673	80.0	7,670	110.5	12,415	141.0	17,574
19.7	887	50.2	3,746	80.6	7,762	111.1	12,519	141.6	17,683
20.3	931	50.8	3,820	81.3	7,855	111.8	12,624	142.2	17,793
21.0	976	51.4	3,894	81.9	7,948	112.4	12,729	142.9	17,903
21.6	1,021	52.1	3,968	82.5	8,041	113.0	12,833	143.5	18,012
22.2	1,067	52.7	4,043	83.2	8,135	113.7	12,938	144.1	18,122
22.9	1,114	53.3	4,119	83.8	8,229	114.3	13,044	144.8	18,232
23.5	1,162	54.0	4,195	84.5	8,323	114.9	13,149	145.4	18,342
24.1	1,210	54.6	4,271	85.1	8,418	115.6	13,255	146.1	18,452
24.8	1,259	55.2	4,348	85.7	8,513	116.2	13,360	146.7	18,562
25.4	1,309	55.9	4,425	86.4	8,608	116.8	13,466	147.3	18,672
26.0	1,360	56.5	4,503	87.0	8,704	117.5	13,572	148.0	18,782
26.7	1,411	57.1	4,581	87.6	8,800	118.1	13,678	148.6	18,892
27.3	1,463	57.8	4,660	88.3	8,896	118.7	13,784	149.2	19,002
27.9	1,516	58.4	4,739	88.9	8,992	119.4	13,891	149.9	19,111
28.6	1,569	59.1	4,819	89.5	9,089	120.0	13,997	150.5	19,221
29.2	1,623	59.7	4,899	90.2	9,186	120.7	14,104	151.1	19,331
29.8	1,678	60.3	4,979	90.8	9,283	121.3	14,211	151.8	19,441
30.5	1,733	61.0	5,060	91.4	9,380	121.9	14,318	152.4	19,551

**DWT6 10'-10000 COMPARTMENT**  
**38,825 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
153.0	19,661	183.5	24,884	214.0	29,788	244.5	34,049	275.0	37,285
153.7	19,771	184.1	24,990	214.6	29,884	245.1	34,128	275.6	37,338
154.3	19,881	184.8	25,097	215.3	29,980	245.7	34,207	276.2	37,391
154.9	19,991	185.4	25,203	215.9	30,076	246.4	34,286	276.9	37,442
155.6	20,101	186.1	25,309	216.5	30,172	247.0	34,364	277.5	37,493
156.2	20,211	186.7	25,415	217.2	30,267	247.6	34,441	278.1	37,544
156.8	20,321	187.3	25,521	217.8	30,362	248.3	34,518	278.8	37,593
157.5	20,431	188.0	25,626	218.4	30,457	248.9	34,595	279.4	37,642
158.1	20,541	188.6	25,732	219.1	30,552	249.6	34,671	280.0	37,690
158.8	20,651	189.2	25,837	219.7	30,646	250.2	34,747	280.7	37,737
159.4	20,761	189.9	25,942	220.3	30,740	250.8	34,822	281.3	37,784
160.0	20,870	190.5	26,047	221.0	30,833	251.5	34,897	281.9	37,830
160.7	20,980	191.1	26,152	221.6	30,927	252.1	34,971	282.6	37,875
161.3	21,090	191.8	26,256	222.3	31,020	252.7	35,045	283.2	37,919
161.9	21,199	192.4	26,361	222.9	31,112	253.4	35,118	283.8	37,963
162.6	21,309	193.0	26,465	223.5	31,204	254.0	35,191	284.5	38,005
163.2	21,419	193.7	26,569	224.2	31,296	254.6	35,264	285.1	38,047
163.8	21,528	194.3	26,673	224.8	31,388	255.3	35,335	285.8	38,088
164.5	21,638	194.9	26,777	225.4	31,479	255.9	35,407	286.4	38,128
165.1	21,747	195.6	26,880	226.1	31,570	256.5	35,478	287.0	38,168
165.7	21,856	196.2	26,984	226.7	31,661	257.2	35,548	287.7	38,206
166.4	21,966	196.8	27,087	227.3	31,751	257.8	35,618	288.3	38,244
167.0	22,075	197.5	27,190	228.0	31,841	258.4	35,687	288.9	38,281
167.6	22,184	198.1	27,292	228.6	31,931	259.1	35,756	289.6	38,317
168.3	22,293	198.8	27,395	229.2	32,020	259.7	35,824	290.2	38,352
168.9	22,402	199.4	27,497	229.9	32,109	260.4	35,891	290.8	38,386
169.5	22,511	200.0	27,599	230.5	32,198	261.0	35,958	291.5	38,419
170.2	22,620	200.7	27,701	231.1	32,286	261.6	36,025	292.1	38,451
170.8	22,729	201.3	27,803	231.8	32,374	262.3	36,091	292.7	38,482
171.4	22,838	201.9	27,905	232.4	32,461	262.9	36,156	293.4	38,512
172.1	22,946	202.6	28,006	233.0	32,548	263.5	36,221	294.0	38,541
172.7	23,055	203.2	28,107	233.7	32,635	264.2	36,285	294.6	38,569
173.4	23,163	203.8	28,208	234.3	32,721	264.8	36,349	295.3	38,596
174.0	23,272	204.5	28,308	234.9	32,807	265.4	36,412	295.9	38,622
174.6	23,380	205.1	28,409	235.6	32,893	266.1	36,475	296.5	38,647
175.3	23,488	205.7	28,509	236.2	32,978	266.7	36,537	297.2	38,670
175.9	23,596	206.4	28,609	236.9	33,063	267.3	36,598	297.8	38,692
176.5	23,704	207.0	28,708	237.5	33,147	268.0	36,659	298.4	38,713
177.2	23,812	207.6	28,808	238.1	33,231	268.6	36,719	299.1	38,733
177.8	23,920	208.3	28,907	238.8	33,315	269.2	36,778	299.7	38,751
178.4	24,027	208.9	29,006	239.4	33,398	269.9	36,837	300.4	38,768
179.1	24,135	209.6	29,104	240.0	33,481	270.5	36,896	301.0	38,783
179.7	24,242	210.2	29,203	240.7	33,563	271.1	36,953	301.6	38,797
180.3	24,349	210.8	29,301	241.3	33,645	271.8	37,010	302.3	38,809
181.0	24,456	211.5	29,399	241.9	33,727	272.4	37,067	302.9	38,818
181.6	24,564	212.1	29,496	242.6	33,808	273.0	37,122	303.5	38,825
182.2	24,670	212.7	29,594	243.2	33,889	273.7	37,177		
182.9	24,777	213.4	29,691	243.8	33,969	274.3	37,232		

# Fiber Glass Systems



## HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

## Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste      Description - PASTE02 - for Salt and Chloride Solutions  
7915 East Elm Street  
Houston, TX 77012  
Phone (713) 926-4780  
E-Mail Sales@KolorKut.com

## Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

## NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West  
Conroe, TX 77303  
Tel: 936-756-7731  
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.