

DWT6 12'-2000 COMPARTMENT
77,718 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	28	24.5	2,372	48.5	6,399	72.5	11,458	96.5	17,250
1.0	45	25.0	2,442	49.0	6,495	73.0	11,572	97.0	17,377
1.5	65	25.5	2,513	49.5	6,592	73.5	11,686	97.5	17,504
2.0	87	26.0	2,585	50.0	6,689	74.0	11,801	98.0	17,632
2.5	111	26.5	2,657	50.5	6,786	74.5	11,916	98.5	17,759
3.0	137	27.0	2,730	51.0	6,884	75.0	12,031	99.0	17,887
3.5	165	27.5	2,804	51.5	6,983	75.5	12,147	99.5	18,015
4.0	195	28.0	2,878	52.0	7,081	76.0	12,263	100.0	18,143
4.5	226	28.5	2,953	52.5	7,181	76.5	12,379	100.5	18,271
5.0	259	29.0	3,029	53.0	7,280	77.0	12,495	101.0	18,400
5.5	294	29.5	3,105	53.5	7,380	77.5	12,612	101.5	18,529
6.0	329	30.0	3,182	54.0	7,480	78.0	12,729	102.0	18,658
6.5	367	30.5	3,259	54.5	7,581	78.5	12,846	102.5	18,787
7.0	405	31.0	3,337	55.0	7,682	79.0	12,964	103.0	18,917
7.5	445	31.5	3,415	55.5	7,784	79.5	13,082	103.5	19,046
8.0	486	32.0	3,494	56.0	7,886	80.0	13,200	104.0	19,176
8.5	528	32.5	3,574	56.5	7,988	80.5	13,319	104.5	19,306
9.0	571	33.0	3,654	57.0	8,091	81.0	13,437	105.0	19,436
9.5	616	33.5	3,735	57.5	8,194	81.5	13,557	105.5	19,567
10.0	661	34.0	3,816	58.0	8,298	82.0	13,676	106.0	19,698
10.5	708	34.5	3,898	58.5	8,402	82.5	13,796	106.5	19,828
11.0	755	35.0	3,981	59.0	8,506	83.0	13,915	107.0	19,959
11.5	804	35.5	4,064	59.5	8,611	83.5	14,036	107.5	20,091
12.0	854	36.0	4,147	60.0	8,716	84.0	14,156	108.0	20,222
12.5	904	36.5	4,231	60.5	8,821	84.5	14,277	108.5	20,354
13.0	956	37.0	4,316	61.0	8,927	85.0	14,398	109.0	20,486
13.5	1,008	37.5	4,401	61.5	9,033	85.5	14,519	109.5	20,618
14.0	1,062	38.0	4,487	62.0	9,140	86.0	14,641	110.0	20,750
14.5	1,116	38.5	4,573	62.5	9,247	86.5	14,762	110.5	20,882
15.0	1,171	39.0	4,660	63.0	9,354	87.0	14,884	111.0	21,015
15.5	1,227	39.5	4,747	63.5	9,462	87.5	15,007	111.5	21,147
16.0	1,284	40.0	4,835	64.0	9,570	88.0	15,129	112.0	21,280
16.5	1,342	40.5	4,923	64.5	9,678	88.5	15,252	112.5	21,413
17.0	1,401	41.0	5,012	65.0	9,787	89.0	15,375	113.0	21,546
17.5	1,460	41.5	5,101	65.5	9,896	89.5	15,498	113.5	21,680
18.0	1,520	42.0	5,190	66.0	10,005	90.0	15,622	114.0	21,813
18.5	1,581	42.5	5,281	66.5	10,115	90.5	15,746	114.5	21,947
19.0	1,643	43.0	5,371	67.0	10,225	91.0	15,870	115.0	22,081
19.5	1,706	43.5	5,462	67.5	10,335	91.5	15,994	115.5	22,215
20.0	1,769	44.0	5,554	68.0	10,446	92.0	16,119	116.0	22,349
20.5	1,833	44.5	5,646	68.5	10,557	92.5	16,243	116.5	22,484
21.0	1,898	45.0	5,739	69.0	10,669	93.0	16,368	117.0	22,618
21.5	1,963	45.5	5,832	69.5	10,781	93.5	16,494	117.5	22,753
22.0	2,030	46.0	5,925	70.0	10,893	94.0	16,619	118.0	22,888
22.5	2,097	46.5	6,019	70.5	11,005	94.5	16,745	118.5	23,023
23.0	2,164	47.0	6,113	71.0	11,118	95.0	16,871	119.0	23,158
23.5	2,233	47.5	6,208	71.5	11,231	95.5	16,997	119.5	23,294
24.0	2,302	48.0	6,304	72.0	11,344	96.0	17,124	120.0	23,429

DWT6 12'-2000 COMPARTMENT
77,718 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	23,565	144.5	30,226	168.5	37,077	192.5	43,965	216.5	50,744
121.0	23,701	145.0	30,368	169.0	37,220	193.0	44,108	217.0	50,883
121.5	23,837	145.5	30,509	169.5	37,364	193.5	44,251	217.5	51,021
122.0	23,973	146.0	30,651	170.0	37,508	194.0	44,394	218.0	51,160
122.5	24,109	146.5	30,792	170.5	37,651	194.5	44,536	218.5	51,299
123.0	24,245	147.0	30,934	171.0	37,795	195.0	44,679	219.0	51,437
123.5	24,382	147.5	31,075	171.5	37,939	195.5	44,822	219.5	51,576
124.0	24,519	148.0	31,217	172.0	38,082	196.0	44,964	220.0	51,714
124.5	24,655	148.5	31,359	172.5	38,226	196.5	45,107	220.5	51,852
125.0	24,792	149.0	31,501	173.0	38,370	197.0	45,249	221.0	51,990
125.5	24,929	149.5	31,643	173.5	38,514	197.5	45,392	221.5	52,128
126.0	25,067	150.0	31,785	174.0	38,657	198.0	45,534	222.0	52,265
126.5	25,204	150.5	31,927	174.5	38,801	198.5	45,676	222.5	52,403
127.0	25,342	151.0	32,069	175.0	38,945	199.0	45,818	223.0	52,541
127.5	25,479	151.5	32,212	175.5	39,088	199.5	45,960	223.5	52,678
128.0	25,617	152.0	32,354	176.0	39,232	200.0	46,102	224.0	52,815
128.5	25,755	152.5	32,496	176.5	39,376	200.5	46,244	224.5	52,952
129.0	25,893	153.0	32,639	177.0	39,520	201.0	46,386	225.0	53,089
129.5	26,031	153.5	32,781	177.5	39,663	201.5	46,528	225.5	53,226
130.0	26,169	154.0	32,924	178.0	39,807	202.0	46,670	226.0	53,363
130.5	26,308	154.5	33,066	178.5	39,951	202.5	46,812	226.5	53,499
131.0	26,446	155.0	33,209	179.0	40,094	203.0	46,953	227.0	53,635
131.5	26,585	155.5	33,352	179.5	40,238	203.5	47,095	227.5	53,772
132.0	26,723	156.0	33,495	180.0	40,382	204.0	47,236	228.0	53,908
132.5	26,862	156.5	33,637	180.5	40,525	204.5	47,378	228.5	54,044
133.0	27,001	157.0	33,780	181.0	40,669	205.0	47,519	229.0	54,180
133.5	27,140	157.5	33,923	181.5	40,813	205.5	47,660	229.5	54,315
134.0	27,280	158.0	34,066	182.0	40,956	206.0	47,801	230.0	54,451
134.5	27,419	158.5	34,209	182.5	41,100	206.5	47,942	230.5	54,586
135.0	27,558	159.0	34,352	183.0	41,243	207.0	48,083	231.0	54,721
135.5	27,698	159.5	34,495	183.5	41,387	207.5	48,224	231.5	54,856
136.0	27,838	160.0	34,638	184.0	41,530	208.0	48,365	232.0	54,991
136.5	27,977	160.5	34,782	184.5	41,674	208.5	48,506	232.5	55,126
137.0	28,117	161.0	34,925	185.0	41,817	209.0	48,646	233.0	55,260
137.5	28,257	161.5	35,068	185.5	41,961	209.5	48,787	233.5	55,395
138.0	28,397	162.0	35,211	186.0	42,104	210.0	48,927	234.0	55,529
138.5	28,537	162.5	35,355	186.5	42,248	210.5	49,068	234.5	55,663
139.0	28,678	163.0	35,498	187.0	42,391	211.0	49,208	235.0	55,797
139.5	28,818	163.5	35,641	187.5	42,534	211.5	49,348	235.5	55,931
140.0	28,958	164.0	35,785	188.0	42,678	212.0	49,488	236.0	56,064
140.5	29,099	164.5	35,928	188.5	42,821	212.5	49,628	236.5	56,197
141.0	29,239	165.0	36,072	189.0	42,964	213.0	49,768	237.0	56,331
141.5	29,380	165.5	36,215	189.5	43,107	213.5	49,907	237.5	56,464
142.0	29,521	166.0	36,359	190.0	43,250	214.0	50,047	238.0	56,597
142.5	29,662	166.5	36,502	190.5	43,393	214.5	50,187	238.5	56,729
143.0	29,803	167.0	36,646	191.0	43,536	215.0	50,326	239.0	56,862
143.5	29,944	167.5	36,789	191.5	43,679	215.5	50,465	239.5	56,994
144.0	30,085	168.0	36,933	192.0	43,822	216.0	50,604	240.0	57,126

DWT6 12'-2000 COMPARTMENT
77,718 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
240.5	57,258	264.5	63,344	288.5	68,812	312.5	73,419	336.5	76,774
241.0	57,390	265.0	63,465	289.0	68,918	313.0	73,504	337.0	76,825
241.5	57,521	265.5	63,586	289.5	69,023	313.5	73,588	337.5	76,876
242.0	57,653	266.0	63,706	290.0	69,128	314.0	73,671	338.0	76,925
242.5	57,784	266.5	63,826	290.5	69,233	314.5	73,754	338.5	76,974
243.0	57,915	267.0	63,946	291.0	69,337	315.0	73,837	339.0	77,021
243.5	58,046	267.5	64,066	291.5	69,441	315.5	73,918	339.5	77,068
244.0	58,176	268.0	64,185	292.0	69,544	316.0	74,000	340.0	77,113
244.5	58,307	268.5	64,304	292.5	69,647	316.5	74,080	340.5	77,157
245.0	58,437	269.0	64,423	293.0	69,750	317.0	74,161	341.0	77,200
245.5	58,567	269.5	64,541	293.5	69,852	317.5	74,240	341.5	77,242
246.0	58,697	270.0	64,659	294.0	69,954	318.0	74,319	342.0	77,283
246.5	58,827	270.5	64,777	294.5	70,056	318.5	74,397	342.5	77,322
247.0	58,956	271.0	64,895	295.0	70,157	319.0	74,475	343.0	77,361
247.5	59,085	271.5	65,012	295.5	70,258	319.5	74,553	343.5	77,397
248.0	59,214	272.0	65,129	296.0	70,358	320.0	74,629	344.0	77,433
248.5	59,343	272.5	65,246	296.5	70,458	320.5	74,705	344.5	77,467
249.0	59,472	273.0	65,362	297.0	70,557	321.0	74,781	345.0	77,500
249.5	59,600	273.5	65,478	297.5	70,656	321.5	74,855	345.5	77,531
250.0	59,728	274.0	65,594	298.0	70,755	322.0	74,930	346.0	77,560
250.5	59,856	274.5	65,710	298.5	70,853	322.5	75,003	346.5	77,588
251.0	59,984	275.0	65,825	299.0	70,951	323.0	75,076	347.0	77,614
251.5	60,111	275.5	65,940	299.5	71,049	323.5	75,148	347.5	77,638
252.0	60,239	276.0	66,054	300.0	71,146	324.0	75,220	348.0	77,660
252.5	60,366	276.5	66,169	300.5	71,242	324.5	75,291	348.5	77,679
253.0	60,493	277.0	66,283	301.0	71,338	325.0	75,361	349.0	77,696
253.5	60,619	277.5	66,396	301.5	71,434	325.5	75,431	349.5	77,709
254.0	60,746	278.0	66,510	302.0	71,529	326.0	75,500	350.0	77,718
254.5	60,872	278.5	66,623	302.5	71,624	326.5	75,568		
255.0	60,998	279.0	66,735	303.0	71,718	327.0	75,636		
255.5	61,123	279.5	66,848	303.5	71,812	327.5	75,702		
256.0	61,249	280.0	66,960	304.0	71,905	328.0	75,769		
256.5	61,374	280.5	67,071	304.5	71,998	328.5	75,834		
257.0	61,499	281.0	67,183	305.0	72,091	329.0	75,899		
257.5	61,624	281.5	67,294	305.5	72,183	329.5	75,963		
258.0	61,748	282.0	67,404	306.0	72,274	330.0	76,026		
258.5	61,872	282.5	67,515	306.5	72,365	330.5	76,088		
259.0	61,997	283.0	67,625	307.0	72,456	331.0	76,150		
259.5	62,120	283.5	67,735	307.5	72,546	331.5	76,211		
260.0	62,244	284.0	67,844	308.0	72,635	332.0	76,271		
260.5	62,367	284.5	67,953	308.5	72,725	332.5	76,330		
261.0	62,490	285.0	68,061	309.0	72,813	333.0	76,389		
261.5	62,613	285.5	68,170	309.5	72,901	333.5	76,446		
262.0	62,735	286.0	68,278	310.0	72,989	334.0	76,503		
262.5	62,858	286.5	68,385	310.5	73,076	334.5	76,559		
263.0	62,980	287.0	68,492	311.0	73,163	335.0	76,614		
263.5	63,101	287.5	68,599	311.5	73,249	335.5	76,668		
264.0	63,223	288.0	68,706	312.0	73,334	336.0	76,722		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.