

DWT6 8'-7000 COMPARTMENT 25,920 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	16	24.5	1,385	48.5	3,764	72.5	6,746	96.5	10,089
1.0	26	25.0	1,427	49.0	3,821	73.0	6,812	97.0	10,161
1.5	38	25.5	1,469	49.5	3,878	73.5	6,879	97.5	10,233
2.0	51	26.0	1,511	50.0	3,935	74.0	6,946	98.0	10,305
2.5	65	26.5	1,553	50.5	3,993	74.5	7,014	98.5	10,378
3.0	80	27.0	1,596	51.0	4,051	75.0	7,081	99.0	10,450
3.5	96	27.5	1,639	51.5	4,109	75.5	7,148	99.5	10,522
4.0	114	28.0	1,683	52.0	4,167	76.0	7,216	100.0	10,595
4.5	132	28.5	1,727	52.5	4,226	76.5	7,284	100.5	10,667
5.0	151	29.0	1,772	53.0	4,285	77.0	7,352	101.0	10,740
5.5	171	29.5	1,817	53.5	4,344	77.5	7,420	101.5	10,812
6.0	192	30.0	1,862	54.0	4,404	78.0	7,488	102.0	10,885
6.5	214	30.5	1,907	54.5	4,463	78.5	7,556	102.5	10,957
7.0	236	31.0	1,953	55.0	4,523	79.0	7,625	103.0	11,030
7.5	259	31.5	1,999	55.5	4,583	79.5	7,693	103.5	11,103
8.0	283	32.0	2,046	56.0	4,643	80.0	7,762	104.0	11,175
8.5	307	32.5	2,093	56.5	4,704	80.5	7,831	104.5	11,248
9.0	333	33.0	2,140	57.0	4,765	81.0	7,900	105.0	11,321
9.5	359	33.5	2,188	57.5	4,826	81.5	7,969	105.5	11,394
10.0	385	34.0	2,236	58.0	4,887	82.0	8,038	106.0	11,467
10.5	412	34.5	2,284	58.5	4,948	82.5	8,107	106.5	11,540
11.0	440	35.0	2,333	59.0	5,010	83.0	8,177	107.0	11,613
11.5	468	35.5	2,382	59.5	5,072	83.5	8,246	107.5	11,686
12.0	497	36.0	2,432	60.0	5,134	84.0	8,316	108.0	11,759
12.5	527	36.5	2,481	60.5	5,196	84.5	8,386	108.5	11,832
13.0	557	37.0	2,531	61.0	5,258	85.0	8,455	109.0	11,905
13.5	587	37.5	2,581	61.5	5,321	85.5	8,525	109.5	11,978
14.0	619	38.0	2,632	62.0	5,384	86.0	8,596	110.0	12,052
14.5	650	38.5	2,683	62.5	5,447	86.5	8,666	110.5	12,125
15.0	683	39.0	2,734	63.0	5,510	87.0	8,736	111.0	12,198
15.5	715	39.5	2,786	63.5	5,573	87.5	8,806	111.5	12,271
16.0	749	40.0	2,838	64.0	5,637	88.0	8,877	112.0	12,344
16.5	782	40.5	2,890	64.5	5,701	88.5	8,948	112.5	12,418
17.0	817	41.0	2,942	65.0	5,765	89.0	9,018	113.0	12,491
17.5	851	41.5	2,995	65.5	5,829	89.5	9,089	113.5	12,564
18.0	887	42.0	3,048	66.0	5,893	90.0	9,160	114.0	12,637
18.5	922	42.5	3,102	66.5	5,958	90.5	9,231	114.5	12,711
19.0	958	43.0	3,155	67.0	6,023	91.0	9,302	115.0	12,784
19.5	995	43.5	3,209	67.5	6,087	91.5	9,373	115.5	12,857
20.0	1,032	44.0	3,263	68.0	6,153	92.0	9,444	116.0	12,931
20.5	1,070	44.5	3,318	68.5	6,218	92.5	9,516	116.5	13,004
21.0	1,108	45.0	3,373	69.0	6,283	93.0	9,587	117.0	13,077
21.5	1,146	45.5	3,428	69.5	6,349	93.5	9,659	117.5	13,151
22.0	1,185	46.0	3,483	70.0	6,415	94.0	9,730	118.0	13,224
22.5	1,224	46.5	3,539	70.5	6,480	94.5	9,802	118.5	13,297
23.0	1,264	47.0	3,595	71.0	6,547	95.0	9,874	119.0	13,370
23.5	1,304	47.5	3,651	71.5	6,613	95.5	9,945	119.5	13,444
24.0	1,344	48.0	3,707	72.0	6,679	96.0	10,017	120.0	13,517

DWT6 8'-7000 COMPARTMENT
25,920 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	13,590	144.5	17,057	168.5	20,296	192.5	23,093	216.5	25,179
121.0	13,663	145.0	17,128	169.0	20,359	193.0	23,145	217.0	25,212
121.5	13,737	145.5	17,198	169.5	20,423	193.5	23,196	217.5	25,245
122.0	13,810	146.0	17,268	170.0	20,486	194.0	23,248	218.0	25,277
122.5	13,883	146.5	17,338	170.5	20,549	194.5	23,298	218.5	25,309
123.0	13,956	147.0	17,409	171.0	20,612	195.0	23,349	219.0	25,340
123.5	14,029	147.5	17,479	171.5	20,674	195.5	23,399	219.5	25,370
124.0	14,102	148.0	17,548	172.0	20,737	196.0	23,449	220.0	25,400
124.5	14,176	148.5	17,618	172.5	20,799	196.5	23,499	220.5	25,430
125.0	14,249	149.0	17,688	173.0	20,861	197.0	23,548	221.0	25,458
125.5	14,322	149.5	17,757	173.5	20,923	197.5	23,597	221.5	25,487
126.0	14,395	150.0	17,827	174.0	20,984	198.0	23,646	222.0	25,514
126.5	14,468	150.5	17,896	174.5	21,046	198.5	23,694	222.5	25,541
127.0	14,540	151.0	17,965	175.0	21,107	199.0	23,742	223.0	25,568
127.5	14,613	151.5	18,034	175.5	21,168	199.5	23,790	223.5	25,593
128.0	14,686	152.0	18,103	176.0	21,228	200.0	23,837	224.0	25,619
128.5	14,759	152.5	18,172	176.5	21,289	200.5	23,884	224.5	25,643
129.0	14,832	153.0	18,241	177.0	21,349	201.0	23,930	225.0	25,667
129.5	14,904	153.5	18,309	177.5	21,409	201.5	23,977	225.5	25,690
130.0	14,977	154.0	18,378	178.0	21,469	202.0	24,022	226.0	25,712
130.5	15,050	154.5	18,446	178.5	21,529	202.5	24,068	226.5	25,733
131.0	15,122	155.0	18,514	179.0	21,588	203.0	24,113	227.0	25,754
131.5	15,195	155.5	18,582	179.5	21,647	203.5	24,158	227.5	25,774
132.0	15,267	156.0	18,650	180.0	21,706	204.0	24,202	228.0	25,793
132.5	15,340	156.5	18,718	180.5	21,764	204.5	24,246	228.5	25,811
133.0	15,412	157.0	18,785	181.0	21,823	205.0	24,290	229.0	25,828
133.5	15,484	157.5	18,853	181.5	21,881	205.5	24,333	229.5	25,845
134.0	15,557	158.0	18,920	182.0	21,939	206.0	24,376	230.0	25,860
134.5	15,629	158.5	18,987	182.5	21,996	206.5	24,418	230.5	25,874
135.0	15,701	159.0	19,054	183.0	22,054	207.0	24,461	231.0	25,886
135.5	15,773	159.5	19,121	183.5	22,111	207.5	24,502	231.5	25,898
136.0	15,845	160.0	19,188	184.0	22,168	208.0	24,543	232.0	25,907
136.5	15,917	160.5	19,254	184.5	22,224	208.5	24,584	232.5	25,915
137.0	15,989	161.0	19,321	185.0	22,281	209.0	24,625	233.0	25,920
137.5	16,061	161.5	19,387	185.5	22,337	209.5	24,665		
138.0	16,132	162.0	19,453	186.0	22,393	210.0	24,704		
138.5	16,204	162.5	19,519	186.5	22,448	210.5	24,744		
139.0	16,276	163.0	19,584	187.0	22,504	211.0	24,782		
139.5	16,347	163.5	19,650	187.5	22,559	211.5	24,821		
140.0	16,418	164.0	19,715	188.0	22,613	212.0	24,859		
140.5	16,490	164.5	19,781	188.5	22,668	212.5	24,896		
141.0	16,561	165.0	19,846	189.0	22,722	213.0	24,933		
141.5	16,632	165.5	19,910	189.5	22,776	213.5	24,970		
142.0	16,703	166.0	19,975	190.0	22,829	214.0	25,006		
142.5	16,774	166.5	20,040	190.5	22,883	214.5	25,041		
143.0	16,845	167.0	20,104	191.0	22,936	215.0	25,077		
143.5	16,916	167.5	20,168	191.5	22,988	215.5	25,111		
144.0	16,986	168.0	20,232	192.0	23,041	216.0	25,145		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.