



USE PARAMETERS:
 PROPER PERFORMANCE OF THE OIL WATER SEPARATOR AND THE QUALITY OF THE EFFLUENT IS BASED UPON THE OPERATIONAL, FUNCTIONAL, & INSTALLATION REQUIREMENTS AS DETAILED IN THE FOLLOWING **CSI** PUBLICATIONS.
 1. OIL/WATER SEPARATOR PRODUCT LITERATURE.
 2. INSTALLATION INSTRUCTIONS: FRP UNDERGROUND STORAGE TANKS. (CSI 6001)
 3. INSTALLATION AND START-UP INSTRUCTIONS FOR UNDERGROUND OWS TANKS. (OWS 2012)

PUB NO. 810MSWCSI-10 JANUARY 2006

DESIGN PARAMETERS:
 THE SEPARATOR IS DESIGNED FOR:
 1. MAXIMUM INFLUENT CAPACITY (IN) _____ PPM
 2. MAXIMUM EFFLUENT CAPACITY (OUT) _____ PPM
 3. MAXIMUM FLOW RATE _____ GPM
 4. NUMBER OF INSTALLED COALESCER PACKS _____

CUSTOMER SIGNATURE ACKNOWLEDGES AND AGREES TO THE USE AND DESIGN PARAMETERS AS DETAILED IN THIS DRAWING AND IN THE REFERENCED PUBLICATIONS AND HEREBY APPROVES FABRICATION. ANY DEVIATION AS OUTLINED MUST BE APPROVED BY **CSI** IN WRITING PRIOR TO MANUFACTURING.

CUSTOMER APPROVAL SIGNATURE: _____
 DATE: _____
 COMPANY: _____
 JOB NAME: _____

CONTAINMENT SOLUTIONS®

**8'-10,000 Gallon SWT G6
 CSI-10 Oil Water Separator**

SPILL CAPACITY: 9,000 GAL	ACTUAL CAPACITY: 9,696 GAL	NOMINAL WEIGHT: 3,550 LBS
------------------------------	-------------------------------	------------------------------